

कार्यालय सहायक अभियन्ता

प्रान्तीय खण्ड, लो०नि०वि० बलिया

पत्रांक- 281 ~~4~~ म्प 19 मी

दिनांक : 17/05/2025

सेवा में,

प्रधानाचार्य

R K MISSION SCHOOL, SAGARPALI
(Nr SAGARPALI Railway Station)
Tehsil BALLIA, Dist:- BALLIA

विषय :- आर० के० मिशन स्कूल भवन के नेशनल बिल्डिंग कोड में प्राविधानित सुरक्षा मानकों के अनुरूप निर्मित किये जाने के सम्बन्ध में।

सन्दर्भ-


आपका पत्रांक RKM / 380 / 2025

दिनांक 16.05.2025

उपरोक्त विषयक सन्दर्भित पत्र के क्रम में सम्बन्धित अवर अभियन्ता के द्वारा दिनांक 20.05.2025 को निरीक्षण किया गया।

निरीक्षण के उपरान्त आपके विद्यालय का निर्माण संलग्न मानक के अनुसार पाया गया।

संलग्नक :- जॉच प्रमाण-पत्र


सहायक अभियन्ता
प्रान्तीय खण्ड लो०नि०वि०
बलिया

कार्यालय सहायक अभियन्ता

प्रान्तीय खण्ड, लो0नि0वि0 बलिया

ANNEXTURE -D

[(CLAUSE 12.2.9 and 13-2.(1))S

No. 281/4/19नी

Dated 7/05/2025

I certify that the Existing Building of **R K MISSION SCHOOL, SAGARPALI Ballia** -situated at Mauza/ SAGARPALI - Arazi No 69,70,71,72,73,74,78/1,78/2 -, Dist Ballia (UP) is Having Blocks /Floor as per Detail Belows

Sn0	Detail of Block(s) in	Block A	Block B	Block C
	School			
1	No of Floor (s) in the	3(G+2)	3(G+2)	3(G+2)
	Blocks			

The building is owned / occupied by **R K MISSION SCHOOL** Compiled with the Building Safety requirements in accordance With National Building code Rules and verified by the Registered Engineer Mr Prafull Chandra Pandey and the Drawings Provided by the owner of the building with the certificate of Structural safety Provided by the owner of the School Building and structural Design Safety certificate given by Engineer Prafull Chandra Pandey The inspection has been done in the presence of Mr Pradeep Kr singh- (Principal. **R K MISSION SCHOOL**) and that the building / premisses is fit for occupancy for running school with effects from **20-05-2025** for periods of **Two Years** in accordance with rules and subjects to compliance of specific conditions as appended.

Assistant Engineer

PD P.W.D BALLIA

जॉच प्रमाण-पत्र

R K MISSION SCHOOL, SAGARPALI Ballia, (Nr SAGARPALI Railway Station) Tehsil BALLIA जि०, बलिया के भवन का निरीक्षण किया गया। निरीक्षणोपरान्त भवन की निम्नांकित मर्दे नेशनल बिल्डिंग कोड के सापेक्ष निम्नलिखित पायी गई।

Sl.No.	Items	Standard	Specification	Remarks
1	Height	3.6 M	N.B.C. 2005 Clause 12.18.1.1	3.40 M
2	Bathroom Height	2.1 M	N.B.C.Clause 12.4.1	3.0 M
3	Open space around the Building	6.0 M	N.B.C.Clause 8.3.1	Satisfactory
4	College Building Area	1.80 ha	N.B.C.Clause 5.5.1(b)iii	Satisfactory
5	Parking Area	1.30 ha	N.B.C.Clause 5.5.1(b)ii (d)	Satisfactory
6	Height of Plinth	0.45 M	N.B.C.Clause 12.1.1	0.60 M
7	Stair Width	1.50 M	N.B.C.Clause 12.18.1.1	1.40 M
8	Lighting and Ventilation Room	1/10 Floor area	As per N.B.C. 2005 Clause 15.1.2	Satisfactory
9	Fire and life Safety	Certified by PHO Ballia	-	-
10	Roofs	R.C.C Flat Roof	As per N.B.C. 2005 Clause 12.19.1	R.C.C. slab
11	Structure	R.C.C. Column and Beam	As per N.B.C. 2005 Clause 12.19.1s	R.C.C. COLUMN AND BEAMS (रजनीश राय रजि० 01/22 RAB Ramdahinpuram BALLIA एर (Er Paful chand Pandey Reg No F 27470 BE CIVIL Engineer) S

अवर अभियन्ता
प्रान्तीय खण्ड लो०नि०वि० बलिया

सहायक अभियन्ता
प्रान्तीय खण्ड लो०नि०वि० बलिया